



Date Submitted: 8/18/2016

## Water Use Efficiency Annual Performance Report - 2015

WS Name: GARFIELD WATER DEPARTMENT

Water System ID# : 27200

WS County: WHITMAN

Report submitted by: *Cody Lord*

### Meter Installation Information:

Estimate the percentage of metered connections: *More Than 75%*

If not fully metered - Current status of meter installation:

*Only 1 location left to meter. Will be completed this year.*

### Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: *01/01/2015 To 12/31/2015*

Incomplete or missing data for the year? *No*

If yes, explain:

### Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	<i>50,943,000</i> gallons
Authorized Consumption (AC) – Annual Volume	<i>39,705,111</i> gallons
Distribution System Leakage – Annual Volume TP – AC	<i>11,237,889</i> gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	<i>22.1 %</i>
3-year annual average	<i>16.6 %</i>

### Goal-Setting Information:

Date of Most Recent Public Forum: *10/28/2009* Has goal been changed since last performance report? *No*

Note: Customer goal must be re-established every 6 years through a public process

### WUE Goals:

Customer Goal (Demand Side):

*- Disseminate water conservation information to residents through the annual consumer confidence report and the town website. - Reduce average per capita water use by 5 gallons per day within 6 years.*

### Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress: